



**PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU**

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2026-27/ 80

Date - 23-4-2026

To,
The Manager
Dundlod Public School
Dundlod

District - Jhunjhunu
Tehsil:- Nawalgarh

Ref- Your letter dated 22.04.26

Date of Exam - 23.04.26

A	Name & Location of Source	IS-10500:2012		Water Sample Dundlod Public School
B	Village/ Town			Dundlod
C	Date Of Collection			22-04-26
D	Lab. Sample No.			C-017
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	8.15
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Residual Chlorine	0.2	1.0	Nil
7	Total Alkalinity[asCaCO ₃]	200	600	390
8	Total Hardness[asCaCO ₃]	200	600	180
9	Chloride[asCl ⁻¹]	250	1000	230
10	Nitrate[as NO ₃ ⁻¹]	45	45	37
11	Fluoride [as F ⁻¹]	1.0	1.5	1.38
12	Sulphate [as SO ₄ ⁻²]	200	400	35
13	TDS	500	2000	896

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.

(S K Sharma)
Junior Chemist

PHED Laboratory Jhunjhunu

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 84

Dated: 24.4.2026

It is certified that an inspection team headed by Surender Kumar Sharma Senior Junior Chemist

(Name of Officers with designation) from PHED Lab Jhunjhuna.....PHED

inspected the Dumdud Public School, Dumdud.....

(Name & Address of the school) on(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 80..... dated 23-4-2026

of PHED Lab Jhunjhuna..... (PHED Lab) certified that

the Dumdud Public School, Dumdud..... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year.....

Signature with Seal: (Surender Kumar Sharma)
Name: कनिष्ठ रसायनज्ञ
Designation: जन स्वास्थ्य अभि० विभाग
Name & Address of the Office / Department: प्रयोगशाला, झुंझुनू

To Manager

Dumdud Public School, Dumdud
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies